



**INSTITUTO DE CIENCIAS
DE LA CONSTRUCCIÓN
EDUARDO TORROJA**

C/ Serrano Galvache, 4. 28033 Madrid (Spain)
Tel.: (+34) 91 302 0440 www.ietcc.csic.es
gestiondit@ietcc.csic.es dit.ietcc.csic.es



European Technical Assessment **ETA 24/ 0160** of 01/ 03/ 2024

English translation prepared by IETcc. Original version in Spanish language

General Part

Technical Assessment Body issuing the European Technical Assessment:
Instituto de Ciencias de la Construcción Eduardo Torroja (IETcc)

Trade name of the construction product

CINGARD® PU600 FLEX

Product family to which the construction product belongs

Liquid Applied Roof Waterproofing Kit, based on polyurethane

Manufacturer

CIN - Corporação Industrial do Norte, S.A.
Av de Dom Mendo, 831 - 4474-009 Maia - Portugal

Manufacturing plant(s)

Plant 1.

This European Technical Assessment contains

6 pages.
+ Annex 1
+ Annex 2 contains confidential information and is not included in this ETA

This European Technical Assessment is issued in accordance with Regulation (EU) No 305/2011, on the basis of

EAD 030350-00-0402
Liquid applied roof waterproofing kits

Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and should be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full (excepted the confidential Annex(es) referred to above). However, partial reproduction may be made, with the written consent of the issuing Technical Assessment Body. Any partial reproduction has to be identified as such.



Specific parts

1 Technical description of the product

The Liquid Applied Roof Waterproofing Kit (LARWK) “CINGARD® PU600 FLEX” is designed and installed in accordance with the manufacturer, design and installation instructions, deposited at the IETcc. This LARWK comprises the following components, which are factory produced by the manufacturer or a supplier.

Components	Trade name	Consumption
Primer	C-Floor® Primer E150DP	0.3 – 0.5 kg/m²
	CINGARD® Primer PU915	0,15 – 0,25 kg/m²
	C-Floor® PU 310 SL	0,15 – 0,25 kg/m²
Internal reinforcement	Fast Fibra de Vidro FV150	-----
Waterproofing membrane	CINGARD® PU600 FLEX	≥ 1,6 kg/m²

This kit can be used for different working life depending mainly of this thickness:

Working life	Minimum quantity consumed	Minimum thickness (mm)
10	CINGARD® PU600 FLEX, 1,6 kg/m²	1,4
	CINGARD® PU600 FLEX, 2 kg/m²	1,6
25	CINGARD® PU600 FLEX	1,8
	2 kg/m² + Fast Fibra de Vidro FV150	

CINGARD® PU600 FLEX is a liquid applied roof waterproofing kits based on polyurethane. It consists of a polyurethane resin, liquid-applied, mono-component, elastomeric with or without internal protection layer. CINGARD® PU600 FLEX reacts with the environmental humidity (direct reaction).

Once polymerised they conform an elastic lining, in form of a layer completely bonded to different supports (steel and other types of metals, concrete, mortar, ceramic, timber, polyurethane foam and other waterproofing membranes like PVC, EPDM and bituminous). Depending on support condition, other type of primer may be advisable.

2 Specification of the intended use in accordance with the applicable European Assessment Document (hereinafter EAD)

2.1 Intended use(s)

The intended use of this System is the waterproofing of roof against the water, as in liquid as vapour form, with any slope between 0 and >30 % (S1-S4), for any type of categorisation of user load between P1 a P4 (annex 1) and resists the effects of low surface temperatures of –20 °C (TL3) and high temperatures of 60 (TH2) to 90 °C (TH4). This LARWK fulfils the Basic works requirements n.º 2 (Safety in case of fire), n.º 3 (Hygiene, health and the environment) and n.º 4 (Safety in use) of the European Regulation 305/11.

This LARWK is made of non load-bearing construction elements. It does not contribute directly to the stability of the roof on which is installed, but it can contribute its durability by providing enhanced protection from the effect of weathering.

This LARWK can be used on new or existing (retrofit) roofs. It can also be used on vertical surfaces (singular details).

2.2 Relevant general conditions for the use of the kit

The provisions made in this European Technical Assessment are based on an assumed working life of 10-25 years from installation in the works, according to EAD030350-00-0402, provided that the conditions lay down for the installation, packaging, transport and storage as well as appropriate use, maintenance and repair are met. In this respect.

The indications given on the working life (W2-W3) cannot be interpreted as a guarantee given neither by the product manufacturer nor by EOTA nor by the Technical Assessment Body issuing this ETA, but are regarded only as a means for choosing the right product in relation to the expected economically reasonable working life of the works.

Installation. The Kit is installed on site. It is the responsibility of the manufacturer to guarantee that the information about design and installation of this system is effectively communicated to the concerned people. This information can be given using reproductions of the respective parts of this ETA. Besides, all the data concerning the execution shall be clearly indicated on the packaging and/or the enclosed instruction sheets using one or several illustrations.



Design. In the MTD the manufacture gives information on the quantities consumed and the processing, which shall lead to a thickness of the roof waterproofing ≥ 1.4 mm.

Execution. Particularly, it is recommended to consider:

- The kit installation has to be carried out by qualified installers,
- it can only be used the components of the kit indicated in this ETA,
- the supervision of the amount of material used (kg/m^2) and the control visual to check that each coat covers totally the one below, can ensure the minimum thickness of the kits,
- inspection of the roof surface (cleanliness and correct preparation) before applying the roof waterproofing,
- the recommended temperature of the product to be assembled will be between 0°C and 40°C and it will be not admitted support temperatures upper to 45°C . In other conditions, it will need to follow the manufacturer's instructions

Before, the installation of CINGARD® PU600 FLEX, it is recommended to read its security card.

Use, maintenance and repair of the works. In those roofs with deteriorated areas of the waterproof layers, they will be repaired carrying out some light grinding to open the pore of the deteriorated layers. Afterwards, the new product will be assembled following the installation instruction and the new coats must overlap, at least 10 cm, to the coat no deteriorated. Further installation details are laid down in the MTD place at IETcc.

3 Performance of the product and references to the methods used for its assessment

The identification tests and the assessment for the intended use of “CINGARD® PU600 FLEX” according to the Basic Work Requirements (BWR) were carried out in compliance with EAD 030350-00-0402. The characteristics of each system shall correspond to the respective values laid down in following tables of this ETA, checked by IETcc.

Methods of verification and of assessing and judging are listed afterwards.

3.1 Safety in case of fire (BWR 2)

Basic requirement for construction works 2: Safety in case of fire		
Essential characteristic	Relevant clause in EAD	Performance
External fire performance of roofs	2.2.1	$B_{\text{roof}}(t_1)$: on Non-combustibles supports NPA: on combustibles supports
Reaction to fire	2.2.2	NPA

3.2 Hygiene, health and environment (BWR 3)

Basic requirement for construction works 3: Hygiene, health, and the environment			
Essential characteristic	Relevant clause in EAD	Performance	
Content, emission and/or release of dangerous substances	2.2.3	NPA	
Resistance to water vapour	2.2.4	$\mu = 1485$ (1.4 mm thickness)	
Watertightness	2.2.5	Watertight	
Resistance to wind loads	2.2.6	Delamination strength: Support + primer + membrane	Pass ≥ 50 kPa (kPa)
		Concrete + without primer	2000
		Concrete + C-Floor® Primer E150DP	2000
		Concrete + Cingard® Primer PU915	700
		Concrete + C-Floor® PU310 SL	840
		Steel + without primer	2600
		Steel + C-Floor® Primer E150DP	2600
		Steel + Cingard® Primer PU915	900
		Steel + C-Floor® PU310 SL	800
		PU foam + any primer	200
Resistance to mechanical damage (perforation)	2.2.7	The failure mode was between support and membrane on concrete – steel support, on the PU support collapse the support P1 - P4 (annex 1)	
		Resistance to static indentation (23 °C)	
	2.2.7.1	2 kg/m ² (without internal mesh)	Steel: I4 (6 mm) PU: I4 (6 mm)
		1,6 kg/m ²	Steel: I4 (6 mm) PU: NPA
	2.2.7.2	Resistance to static indentation (23 °C)	
		2 kg/m ² (without internal mesh)	Steel: L4 (25 kg) PU: L3 (20 kg)



Resistance to mechanical damage (perforation)		1,6 kg/m ²	Steel: L3 (20 kg) PU: NPA
Resistance to fatigue movement	2.2.8	W3 1000 cycles (-10 °C) with any mesh- 2 kg/m ² W2 500 cycles (-10 °C) without mesh- 1,6 kg/m ²	
Resistance to the effects of low and high surface temperatures	2.2.9	Low temperatures: TL3 High temperatures: TH2-TH4	
	2.2.9.1	R. Dynamic Indentation at TL3	
		2 kg/m ² (without internal mesh)	Steel: I4 (6 mm) at -20 °C PU: I4 (6 mm) at -20 °C
		1,6 kg/m ²	Steel: I4 (6 mm) at -20°C On PU: NPA
	2.2.9.3	R. Static indentation (60 – 90 °C)	
		2 kg/m ² (without internal mesh)	Steel: L2 (15 kg) at 90 °C Steel: L3 (20 kg) at 80 °C Steel: L4 (25 kg) at 60 °C PU: L1 (7 kg) at 60 °C
			Steel: L3 (20 kg) at 80 °C Steel: L1 (7 kg) at 90 °C PU: NPA
			Steel: L3 (20 kg) at 90 °C Steel: L4 (25 kg) at 80 °C PU: NPA
		1,6 kg/m ²	
		2 kg/m ² With Internal reinforcement (+ internal mesh)	Steel: L3 (20 kg) at 90 °C Steel: L4 (25 kg) at 80 °C PU: NPA
Resistance to ageing media (heat and water)	2.2.10.1	Resistance to heat ageing W2- W3, S (severe) (100 - 200 days at 80 °C)	
		R. Dynamic Indentation (-20 °C) W3	
		2 kg/m ² (without internal mesh)	Steel: I4 (6 mm) at -20 °C PU: I4 (6 mm) at -20 °C
		1,6 kg/m ²	Steel: I4 (6 mm) at -20 °C PU: NPA
		Fatigue movement (50 cycles) at -10 °C: Pass	
		Tensile properties (MPa / %)	
		1,6 kg/m ² W2 (without internal mesh)	Initial: 3.5 / 694
		2 kg/m ² W3 (without internal mesh)	Initial: 2.4 / 460 Ageing: 3.3 / 192
		2 kg/m ² W3 + internal mesh	Initial: 6 / 6
	2.2.10.3	Resistance to water ageing W2 –W3, S1-S2, P4 (30 – 60 -180 days at 60 °C)	
		R. Static indentation	
		2 kg/m ² - 60d (without internal mesh)	90 °C -Steel: L2 (15 kg) 80 °C -Steel: L3 (20 kg) 60 °C -Steel: L4 (25 kg)
			90 °C -Steel: L1 (7 kg)
			80 °C -Steel: L2 (15 kg) 60 °C -Steel: L3 (20 kg)
		1,6 kg/m ² – 30d	
		2 kg/m ² + Internal mesh - 60d 60 -90 °C -Steel: L3 (20 kg)	
		Resistance to delamination (kPa) ≥ 50 kPa (60 / 180 days)	
		Concrete + without primer	NPA
		Concrete + C-Floor® Primer E150DP	3000 / 2000
Resistance to UV radiation in the presence of moisture	2.2.10.2	W3-W2, S (severe), 5000-2000 hours without finishing layers	
		R. Dynamic Indentation (-20 °C) W3	
		2 kg/m ² (without internal mesh)	Steel: I4 (6 mm) PU: I4 (6 mm)
		1,6 kg/m ²	Steel: I4 (6 mm) PU: NPA
		Tensile properties (MPa / %)	
		2 kg/m ² W2 (without internal mesh)	Initial: 2.4 / 460 Ageing: 3.1 / 193
Resistance to plant roots	2.2.11	NPA	
Effects of variations in kit components and site practices	2.2.12	2 kg/m ² (without internal mesh)	
		0 °C. Tensile properties (MPa / %)	
		40 °C. Tensile properties (MPa / %)	
		0 °C. R. Dynamic Indentation	
Effects of the days joint	2.2.13	40 °C. R. Dynamic Indentation	
		Delamination strength: 1800 kPa	



3.3 Safety and accessibility in use (BWR 4)

Basic requirement for construction works 4: Safety and accessibility in use		
Essential characteristic	Relevant clause in EAD	Performance
Slipperiness	2.2.14	NPA

4 Assessment and verification of constancy of performance (hereinafter AVCP) system applied, with reference to its legal base

4.1 System of assessment and verification of constancy of performance

According to the decision 98/599/EC of October 1998, Official Journal of the European Communities N.º L 287, 24.10.1998) of the European Commission¹, system 3 of assessment and verification of constancy of performance (see EC delegated regulation (EU) No 568/2014 amending Annex V to Regulation (EU) N° 305/2011) applies.

Product	Intended uses	Level or Classes	System
CINGARD® PU600 FLEX	Liquid Applied Roof Waterproofing Kit	Any	3

5 Technical details necessary for the implementation of the AVCP system, as provided for in the applicable EAD

Technical details necessary for the implementation of the AVCP system are laid down in the control plan which is deposited at IETcc².

5.1 Tasks of the manufacturer

Factory production control. The manufacturer shall exercise permanent internal control of production. All the elements, requirements and provisions adopted by the manufacturer shall be documented in a systematic manner in the form of written policies and procedures, including records of results performed. This production control system shall ensure that the product is in conformity with this ETA.

The manufacturer may only use components stated in the technical documentation of this ETA including Control Plan. The incoming raw materials are subjected to verifications by the manufacturer before acceptance.

The factory production control shall be in accordance with the Control Plan. The results of factory production control shall be recorded and evaluated in accordance with the provisions of the Control Plan

Other tasks of the manufacturer. The manufacturer shall make a declaration of conformity, stating that the construction product is in conformity with the provisions of this ETA.

5.2 Tasks of notified bodies.

Initial type-testing of the product. For type testing, the results of the tests performed as part of the assessment for the European Technical Assessment shall be used unless there are changes in the production line or plant. In such cases, the necessary type testing has to be agreed between IETcc and the notified body.

The initial type-testing have been conducted by the IETcc to issue this ETA in accordance with the EAD 030350-00-0402 "Liquid applied roof waterproofing kits". The verifications underlying this ETA have been furnished on samples from the current production.

¹ Published in the Official Journal of the European Union (OJEU) L 262, 14/10/2003 P. 0034 - 0036.
See www.new.eur-lex.europa.eu/oj/direct-access.html

² The Control Plan is a confidential part of the ETA and only handed over to the notified certification body involved in the assessment and verification of constancy of performance.



Issued in Madrid on 1 of march 2024

By

Director
on behalf of Instituto de Ciencias de la Construcción Eduardo Torroja (IETcc – CSIC)

Annex 1

Resistance to mechanical damage (perforation) CINGARD® PU600 FLEX

Niveles	1,6 kg/m²	2 kg/m²	2 kg/m² + Fast Fibra de Vidro FV150
Working life	W2 (10 years)	W3 (25 years)	
User load	Concrete/steel		
	P3: TH2 P2: TH3 P1: TH4	P3: TH2 P3: TH3 P2: TH4	P4: TH2, TH3 P3: TH4

NOTE: For a polyurethane foam support, the system has only been tested for a working life of 10 years (W2) and 2 kg/m² o CINGARD® PU600 FLEX and a User Load of P1.

